



SALES SPECIFICATION

Port Edwards, WI

# Liquid Chlorine

(Cl<sub>2</sub>)

COMPONENT	LIMIT
Chlorine, % (volume)	99.5 min.
Moisture, ppm (weight)	50 max.
Total Trihalomethanes, ppm (weight)	300 max.
Nonvolatile residue, ppm (weight)	50 max.

Meets current test requirements of **ANSI/AWWA Standard B301**.

NSF listed as complying with **NSF/ANSI/CAN Standard 60**.

Meets current test requirements of **ASTM Standard E1120**.

Meets current **Food Chemical Codex** specifications.

**Star-K Kosher** Certified

**IFANCA® Halal** Certified

The information presented is not guaranteed although it was prepared by ERCO's technical personnel and is intended to be accurate to the best of our knowledge. No warranties or guarantees, expressed or implied, are made regarding performance, stability, or otherwise. This information is not intended to be all-inclusive as the conditions of use, handling, storage, and other factors may involve additional safety or performance considerations.